



west virginia department of environmental protection

Division of Water and Waste Management
601 57th Street, SE
Charleston, WV 25304
Phone: 304-926-0495 / Fax: 304-926-0463

Harold D. Ward, Cabinet Secretary
dep.wv.gov

MEMORANDUM

TO: Katheryn Emery, P.E., Director, DWWM

FROM: Michael King, P.E., DWWM

DATE: June 11, 2025

SUBJECT: City of Hinton
IJDC No. 2015S-1585
CSO Abatement – Phase 1
Use of Contingency Request - Engineering Amendment No. 2 and CO3

RECOMMENDATION

The Use of Contingency Request prepared by Region I Planning and Development Council for the above referenced project has been reviewed and is technically feasible.

Engineering Amendment 2 includes an additional 62 days of inspection during the months of April and May and the total cost is \$65,600.00. This request is for additional engineering fees for inspection and engineering during construction services. The contract time of contract 1 being extended by 150 days as stated in Change Order 3. A portion of the 150 days (88 days) during the months of January through March was paid for by the contractor (RDRUSG).

In addition, Change Order No. 3, increases the Contract Amount by \$30,530.81. Work associated with CO 3 includes the installation of an emergency Force Main connection at the bridge crossing the Greenbrier River. This CO also includes a price increase associated with the rearrangement of two grinder pump stations along Greenbrier Drive and the widening of the fence at the new Bellepoint pump station.