



west virginia department of environmental protection

Division of Water and Waste Management
601 57th Street, SE
Charleston, WV 25304
Phone: 304-926-0495 / Fax: 304-926-0463

Harold D. Ward, Cabinet Secretary
dep.wv.gov

MEMORANDUM

TO: Katheryn Emery, P.E., Engineer Chief, DWWM

FROM: Daniel Bailey, E.I., CFM, DWWM

DATE: June 13, 2025

SUBJECT: City of Richwood
IJDC No. 2018S-1779
Sanitary Sewer Improvements - Ph. 1 Project
Use of Contingency Request

RECOMMENDATION

The Use of Contingency Request prepared by The Thrasher Group, Inc. for the above referenced project has been reviewed and is technically feasible.

The estimated cost for this work is \$125,722.03 and proposes to utilize IJDC contingency.

This request is to adjust a portion of line 22 along Riverside Dr. through Oakford Ave. intersection and up Maple St. to the last lot before the crest of the hill. Existing waterlines and other utilities along the roadway do not allow for 4-foot diameter manholes and will call for a pressure pipe along the alignment. The existing sewer line serving customers behind the Catholic Church is clogged and filled with sediment. This line will be replaced allowing restored service to those customers. The sewer service along Boggs and Maple were found to be combined with storm sewer lines and discharge directly into the Cherry River. These lines will be replaced with sewer lines connecting to Line 22 and the existing storm sewer line will be extended and discharged properly. A net adjustment for work competed in Change Order #2 is included to offset the cost of this proposed change.